



Town of Amherst
Fire Safety Division
5583 Main Street
Williamsville, New York 14221
Phone: (716) 631-7080
Fax: (716)631-7192

SMOKE & CARBON MONOXIDE DETECTOR CERTIFICATION

Date: _____

The installation of smoke and/or carbon monoxide detectors was completed at the following address: _____

Smoke Detectors:

An operable and properly installed smoke detector has been installed at the following locations:

- All bedroom/guest rooms
- Area outside bed/guest room(s) (Within 21ft per NFPA 72).
- On all levels of dwelling unit including basements.

Carbon Monoxide Detectors:

An operable and property installed carbon monoxide detector has been installed at the following locations: **(Not required when entire building is all electric)**

- On every level where there is a source.
- 15 feet from the door(s) to the bed/guest room(s)
 - If the source does not provide forced/re-circulated air (boiler/heat pump heat), then detector(s) are only required on the lowest level of sleeping rooms.
- Within each bed/guest room containing a source.

Owner/Manager: _____

Signature: _____

Address: _____

Phone number: _____

****Submittal of this document constitutes completion/compliance of the requirements listed above. You may be subject to an inspection for verification of compliance. Further legal action may be pursued if full compliance is not found. Please do not hesitate to call for any questions****