



TOWN OF AMHERST
Fire Safety Division
 5583 Main St – Lower Level
 Amherst, New York 14221
 Phone (716) 631-7140
 Email: firesafety@amherst.ny.us
www.amherst.ny.us/firesafety

PRIVATE HYDRANT INSPECTION

The Private Fire Hydrant Inspection Report ensures compliance with the NYS Fire Code and NFPA 25 by documenting the condition, maintenance, and operability of private fire hydrants. Inspections verify proper water flow, physical integrity, and operational readiness to ensure hydrants function effectively during emergencies. Accurate reporting supports fire safety and regulatory adherence.

Address:	Date:
Property Name:	
Hydrant Location:	
Manufacture & Date (On Hydrant):	
Inspector / Company:	Phone:

YES = Satisfactory NO = Unsatisfactory (Explain in Comments)

<u>Service Completed:</u>	YES	NO
Hydrant caps slightly more than hand tight.		
There are no leaks in the top of the hydrant.		
There are no leaks in the gasket under caps.		
There are no cracks in the hydrant barrel.		
Hydrant drains properly.		
Operating nut is not worn and does not have rounded corners.		
Outlet threads are not damaged.		
Lubricate operating nut.		
Lubricate packing.		
Lubricate thrust collar.		
Hydrant flushed until clear. (1 minute Minimum)		
Clearly visible, clear access to & around Hydrant (3' Minimum) ("Main Connection" facing towards road/drive)		
Center Steamer nut height to grade (18" - 36").		
Hydrant is RED in color. (Paint in good condition)("Safety Red")		
Hydrant has marker.		

<u>Flow Test: (Every 5 Years MINIMUM)</u>	<u>Last Performed:</u>
Static Pressure: (PSI)	Flow Rate: (GPM)
Residual Pressure: (PSI)	@ 0 PSI: (GPM)
Pitot Pressure: (PSI)	@ 20PSI: (GPM)
Outlet Size Used: (Inches)	Coefficient:

COMMENTS:
